

BEFORE THE ELEVATOR SAFETY BOARD
STATE OF ARKANSAS

IN RE: RANDOLPH COUNTY COURTHOUSE
 DAVID JANSEN, RANDOLPH COUNTY JUDGE

AMENDED CONSENT ORDER


This matter comes before the Arkansas Elevator Safety Board on Thursday, August 6, 2015. The petitioner, Randolph County Judge David Jansen, seeks a variance for an inclined chair lift to be installed at Randolph County Courthouse, 107 West Broadway, Pocahontas, Arkansas 72455. The petitioner seeks variance from the overhead clearance requirement (60") contained in A18.1-2005 Section 3.1.2.2. The agency and petitioner agree that there is an undue hardship in this matter and that reasonable safety will be secured with the following conditions:

- a. installation of a "kill switch" to ensure the conveyance will not operate if the rider is not in a sitting position; and
- b. limit key access to certain county personnel; and
- c. addition of signage on landings to indicate low clearance; and
- d. the conveyance shall be properly inspected and permitted under the Arkansas Elevator Safety Law.


THEREFORE, the Board concludes that an undue hardship is present in this matter and that reasonable safety will be secured if this request is granted pursuant to the conditions contained above. The conditions shall be completed by February 6, 2016.


IT IS SO ORDERED.

ELEVATOR SAFETY BOARD
STATE OF ARKANSAS

By: 
Leon Jones, Jr., Chairman

Date: 8/19/15

Approved:  8/19/15
Daniel Knox Faulkner, 2002-168 DATE
Staff Attorney
Arkansas Department of Labor
10421 West Markham Street
Little Rock, AR 72205
(501) 682-4504

 8-18-15
The Honorable David Jansen DATE
Randolph County Judge
107 West Broadway
Pocahontas, AR 72455
(870) 892-5264